We help ideas meet the real world

Test Certificate / Part Certificate

No. DK0199-R60-15.04

Issued by **DELTA Danish Electronics, Light & Acoustics**
EU - Notified Body No. 0199

In accordance with EN 45501 (1992), paragraph 8.1 and 3.5.4
with fraction p_{LC} = 0.7
OIML R60 (Edition 2000), WELMEC 2.4. (2001)

Issued to **Hana Elektronik Tartıi Sanayi Ticaret Anonim Şirketi**
Akçaburgaz Mahallesi Alkop Sanayi Sitesi B-4, Blok No:14
Esenyurt – Istanbul
TURKEY

In respect of Bending beam load cell, with strain gauges

Type HL-L6G / HL-L6T / HL-L6F
Manufacturer Hana Elektronik Tartıi San. Tic. A.Ş.

Description and documentation The load cell is described and documented – including a summary of the tests - in the Annex which forms part of this test certificate.

Table 1: Essential data

Type designation		HL-L6G / HL-L6T	HL-L6F
Accuracy class acc. to OIML R60		C6	C5
Maximum number of intervals	n_{LC}	6000	5000
Maximum capacity	E_{max}	50 to 250 kg	50 to 635 kg
Apportionment factor	p_{LC}	0.7	
Minimum verification interval [$\%E_{max}$]	v_{min}	0.0066 %	
Ratio of min LC verification interval	Y	15000	
Minimum dead load output return [$\%E_{max}$]	DR	0.0083 %	0.0092 %
Ratio of minimum dead load output return	Z	6000	5400
Rated output (sensitivity)	C_n	2 mV/V	
Load cell material		Aluminium	

The annex comprises 7 pages.

Issued on **2015-01-26** **Signatory: J. Hovgård**

DELTA
Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. (+45) 72 19 40 00
Fax (+45) 72 19 40 01
www.delta.dk
VAT No. DK 12275110

DANAK
PROD Reg. nr 7026